


PTW Safety Checklist No. 27



OPERATIONS OF PORTABLE DIESEL AND IC ENGINES

Other Checklists that may be relevant:		24
Permit Number:		Date:
Rev 2.2	Issue Date: 29/11/2023	Authorised By: PSM

CAUTION:

- 1 The use of non-zone rated engines in a Zone 2 Area will be allowed with the following controls in place:**
 - a) Initial and continuous gas testing
 - b) Equipment is continuously manned while in operation.
- 2 The engine shall be located as far from the process as practical.**

PRIOR TO PERMIT ISSUE:

	Y	N	N/A
3 Indicate the area / zone on the attached map where the equipment is to be located.	<input type="checkbox"/>		
4 Indicate area as either Zone 2 or Non-hazardous.			
<input type="checkbox"/> <input type="checkbox"/>			
5 Have the controls, as agreed with the PI to cover use of non-zone rated engines in Zone 2 areas been recorded in the JHA?	<input type="checkbox"/>		<input type="checkbox"/>
6 A dedicated watch person is nominated to shut down the engine in the event of an emergency:	<input type="checkbox"/>		
Name: _____			
7 Ensure vehicle has a fully functional fire extinguisher fitted.	<input type="checkbox"/>		
8 Equipment has a current WOF / COF as required.	<input type="checkbox"/>		<input type="checkbox"/>
9 Equipment checked and found to be in good condition e.g., free from leaks.	<input type="checkbox"/>		