


PTW Safety Checklist No. 31



WORKING with a NUCLEAR DENSITY METER (NDM)

Other Checklists that may be relevant:		00, 18,
Permit Number:		Date:
Rev 2.0	Issue Date: 01/04/2025	Authorised By: PSM

CAUTION:

1	Personal monitoring devices are required as stated in ORS C12 (Code of Practice for Sealed Radioactive Material) 2020
2	When using Radiographic inspection equipment use Checklist 28 Radiography

PRIOR TO PERMIT ISSUE:

		Y	N	N/A
3	A site plan has been provided which includes the location of testing, exclusion zones, barriers / warning signs	<input type="checkbox"/>		
4	All NDM testing must be conducted in accordance with the 'Radiation Safety Act 2016' and ORS C12 'Code of Practice for Sealed Radioactive Material' 2020	<input type="checkbox"/>		
5	Name and signature of the person responsible for, and the operation of, the NDM	<input type="checkbox"/>		

PRIOR TO COMMENCING TASK:

- 6** PICWS must:
- Attend all movements of test equipment around the site
 - Ensure test equipment is in good condition and has current certification
 - Ensure test equipment is safely secured when not in use
 - Ensure the integrity of the radiation safety barriers and control access to the exclusion zone
-